

Ref: ESV210185/00

15 June 2021

Tridonic Australia Pty Ltd.

2/7 Millner Ave  
Horsley Park NSW 2175

Dear Sir/Madam,

**APPROVAL OF IN-SCOPE ELECTRICAL EQUIPMENT**

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria.

Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the certificate.

Should you have any queries, please contact David Eddy on telephone 03 9203 9795 or email [David.Eddy@energysafe.vic.gov.au](mailto:David.Eddy@energysafe.vic.gov.au)

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change to the registered business name or address within 20 business days.

Yours sincerely



Neil Fraser

**ACTING DIRECTOR OF ENERGY SAFETY**

# Certificate of Conformity

This is to certify that the Acting Director of Energy Safety has approved the electrical equipment described hereunder.

**Certificate Holder:** Tridonic Australia Pty Ltd.  
2/7 Millner Ave  
Horsley Park NSW 2175

**Required Marking:** Regulatory Compliance Mark (RCM)

Electrical equipment covered by this certificate must comply in all respects with the certified article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification must be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

## ARTICLE DETAILS

Electrical Equipment:	Level 3 Power Supply or Charger - Power Supply Constant current non-dimming LED driver: independent type
Relevant Standards:	AS/NZS 61347.1:2016+A1 & AS 61347.2.13:2018
Expiry Date:	10 June 2026
Conditions of Approval:	

Acting Director of Energy Safety

## Additional details

Model	LC 20/100-1050/44 NF SR EXC3
Rated at	Input: 220-240 V, 24.5 W, 50/60 Hz Output: 60 Vdc, 20 W, 100-1050 mA
Trade Name	TRIDONIC
Comments	

Model	LC 27/100-500/54 NF SR EXC3
Rated at	Input: 220-240 V, 31.7 W, 50/60 Hz Output: 60 Vdc, 27 W, 100-500 mA
Trade Name	TRIDONIC
Comments	

Model	LC 45/450-1050/54 NF SR EXC3
Rated at	Input: 220-240 V, 50.9 W, 50/60 Hz Output: 60 Vdc, 45 W, 450-1050 mA
Trade Name	TRIDONIC
Comments	

