

Ref: ESV210228/00

23 July 2021

Tridonic Australia Pty Ltd.

2/7 Millner Ave
Horsley Park NSW 2175

Dear Sir/Madam,

APPROVAL OF IN-SCOPE ELECTRICAL EQUIPMENT

Enclosed is the Certificate(s) in respect to your recent application received by Energy Safe Victoria.

Please take time to check the certificate to ensure that all details are correct in accordance with your application, and that you understand all of the conditions imposed on the certificate.

Should you have any queries, please contact Naveen Kapoor on telephone 03 9203 9774 or email Naveen.Kapoor@energysafe.vic.gov.au

Any samples that accompanied your application are available for collection, and if not collected within 20 business days of the date hereon may be disposed of.

Notification must be given to Energy Safe Victoria of any change to the registered business name or address within 20 business days.

Yours sincerely



Adam Murdoch

HEAD OF ELECTRICAL EQUIPMENT SAFETY AND EFFICIENCY

Certificate of Suitability

This is to certify that the Head of Electrical Equipment Safety and Efficiency has approved the electrical equipment described hereunder.

Certificate Holder: Tridonic Australia Pty Ltd.
2/7 Millner Ave
Horsley Park NSW 2175

Required Marking: Regulatory Compliance Mark (RCM)

Electrical equipment covered by this certificate must comply in all respects with the certified article, and prior to being supplied or offered for supply, must be clearly and indelibly marked with the Regulatory Compliance Mark (RCM) provided that the requirements of all relevant parts of AS/NZS 4417 applicable to the article are fulfilled.

Any modifications to the electrical equipment or its place of manufacture must be approved by Energy Safe Victoria prior to the equipment being supplied or offered for supply.

Notification must be given to Energy Safe Victoria of any change to the name or address of the holder of the certificate within 20 business days.

ARTICLE DETAILS

Electrical Equipment:	Level 1 Constant current dimming LED driver: inbuilt type
Relevant Standards:	AS/NZS 61347.2.13:2013 & AS/NZS 61347.1:2016+A1
Expiry Date:	23 July 2026
Conditions of Approval:	Alternate approval marking ESV200181

Additional details

dimming LED driver for inbuilding

Model	LC 50W 100-400mA flexC Ip EXC
Rated at	Input: 220-240 V, 54 W, 50/60 Hz Output: 50-250 Vdc, 50 W, 100-400 mA
Trade Name	TRIDONIC
Comments	

Model	LC 75W 100-400mA flexC Ip EXC
Rated at	Input: 220-240 V, 80.9 W, 50/60 Hz Output: 50-250 Vdc, 75 W, 100-400 mA
Trade Name	TRIDONIC
Comments	

Model	LC 75W 250-550mA flexC Ip EXC
Rated at	Input: 220-240 V, 81 W, 50/60 Hz Output: 250 Vdc, 75 W, 250-550 mA
Trade Name	TRIDONIC
Comments	

Model	LC 75W 350-1050mA flexC Ip EXC
Rated at	Input: 220-240 V, 81.3 W, 50/60 Hz Output: 250 Vdc, 75 W, 350-1050 mA
Trade Name	TRIDONIC
Comments	

Model	LC 100W 250-700mA flexC Ip EXC
Rated at	Input: 220-240 V, 106 W, 50/60 Hz Output: 250 Vdc, 100 W, 250-700 mA
Trade Name	TRIDONIC
Comments	

Model	LC 150W 200-1050mA sl EXC
Rated at	Input: 220-240 V, 158 W, 50/60 Hz Output: 400 Vdc, 150 W, 200-1050 mA
Trade Name	TRIDONIC
Comments	

Model	LC 150W 200-1050mA IND sl EXC
Rated at	Input: 220-240 V, 158 W, 50/60 Hz Output: 400 Vdc, 150 W, 200-1050 mA
Trade Name	TRIDONIC
Comments	

Model	LC 25W 100-500mA flexC lp EXC
Rated at	Input: 220-240 V, 29.2 W, 50/60 Hz Output: 60 Vdc, 25 W, 100-500 mA
Trade Name	TRIDONIC
Comments	

Model	LC 50W 350-1050mA flexC lp EXC
Rated at	Input: 220-240 V, 56.2 W, 50/60 Hz Output: 60 Vdc, 50 W, 350-1050 mA
Trade Name	TRIDONIC
Comments	

Model	LC 75W 900-1800mA flexC lp EXC
Rated at	Input: 220-240 V, 84.5 W, 50/60 Hz Output: 60 Vdc, 75 W, 900-1800 mA
Trade Name	TRIDONIC
Comments	