

Attestation of Conformity

No. N8AUK 079054 0051 Rev. 00

Holder of Certificate: **Tridonic GmbH & Co KG**


Färbergasse 15
6851 Dornbirn
AUSTRIA

Product: **Power supplies
(LED Driver)**

This Attestation of Conformity is issued on a voluntary basis according to the Electrical Equipment (Safety) Regulations 2016 relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the regulations and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 6814022002101

Date, 2022-01-24



(Taylor Yao)

Page 1 of 2

After preparation of the necessary UK regulation technical documentation as well as the UK declaration of conformity the required UKCA marking can be affixed on the product. Other applicable UK regulations have to be observed.

Attestation of Conformity

No. N8AUK 079054 0051 Rev. 00

Model(s): LC 10/200-350/29 flexC Ip SNC4

Brand: TRIDONIC



Parameters:

Rated Input Voltage : 220-240VAC/DC
 Rated Frequency : 50/60Hz (for 220-240VAC)
 Rated Input Current : 0.056A
 Rated Output : See below table for details
 Protection against Electric Shock : SELV
 Method of Installation : Built-in
 Type of Output : Constant current type
 tc : See below table for details

Model	Output Voltage (VDC)	I _{rated} (mA)	U _{out} (VDC)	P _{rated} (W)	Value of tc (°C)
LC 10/200-350/29 flexC Ip SNC4	14-29	200	37	5.8	80
		250		7.3	85
		300		8.7	85
		350		10.2	85

Tested according to: EN 61347-1:2015/A1:2021
 EN 61347-2-13:2014/A1:2017