

Attestation of Conformity

No. N8AUK 079054 0050 Rev. 00


Holder of Certificate: **Tridonic GmbH & Co KG**
Färbergasse 15
6851 Dornbirn
AUSTRIA

Product: **Power supplies
(LED Driver)**

This Attestation of Conformity is issued on a voluntary basis according to the Electrical Equipment (Safety) Regulations 2016 relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the regulations and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 6814021053601

Date, 2022-01-24



(Taylor Yao)

Attestation of Conformity

No. N8AUK 079054 0050 Rev. 00

Model(s): LC 19/200-350/54 flexC Ip SNC4;
 LC 38/400-700/54 flexC Ip SNC4;
 LC 57/700-1050/54 flexC Ip SNC4;
 LC 75/1100-1400/54 flexC Ip SNC4

Brand: TRIDONIC



Parameters:

Rated Input Voltage : 220-240VAC/DC
 Rated Frequency : 50/60Hz (for 220-240VAC)
 Rated Input Current : See below table for details
 Rated Output : See below table for details
 Protection against Electric Shock : SELV
 Method of Installation : Built-in
 Type of Output : Constant current type
 tc : See below table for details

Model	Rated Input Current (A)	Output Voltage (VDC)	I _{rated} (mA)	U _{out} (VDC)	P _{rated} (W)	Value of tc (°C)
LC 19/200-350/54 flexC Ip SNC4	0.100	20-54	200	60	10.8	75
			250		13.5	75
			300		16.2	80
			350		18.9	80
LC 38/400-700/54 flexC Ip SNC4	0.191	20-54	400	60	21.6	80
			500		27.0	85
			600		32.4	85
			700		37.8	90
LC 57/700-1050/54 flexC Ip SNC4	0.282	20-54	700	60	37.8	85
			850		45.9	90
			900		48.6	90
			1050		56.7	90
LC 75/1100-1400/54 flexC Ip SNC4	0.370	20-54	1100	60	59.4	85
			1200		64.8	85
			1300		70.2	90
			1400		75.6	90

Tested according to: EN 61347-1:2015/A1:2021
 EN 61347-2-13:2014/A1:2017