

# CERTIFICATE

No. U6 079054 0052 Rev. 01

**Holder of Certificate:** **Tridonic GmbH & Co KG**

Färbergasse 15  
6851 Dornbirn  
AUSTRIA

**Certification Mark:**




**Product:** **Power supplies  
(LED Driver)**

The product was voluntarily tested according to the listed standards. The product can be marked with the certification mark shown above. It is not permitted to alter the certification mark in any way. In addition, the certificate holder must not transfer the certificate to third parties. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 64142215020902

**Date,** 2023-05-30



( Taylor Yao )



Product Service

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT

# CERTIFICATE

No. U6 079054 0052 Rev. 01

**Model(s):** LC 10/200-350/29 flexC Ip SNC4

**Brand Name:** TRIDONIC



### Parameters:

Rated Input Voltage: 220-240VAC/DC  
 Rated Frequency: 50/60Hz (for 220-240VAC)  
 Rated Input Current: 0.056A  
 Rated Output: See below table for details  
 Protection against Electric Shock: SELV  
 Method of Installation: Built-in  
 Type of Output: Constant current type  
 tc: See below table for details

Model	Output Voltage (VDC)	I <sub>rated</sub> (mA)	U <sub>out</sub> (VDC)	P <sub>rated</sub> (W)	Value of tc (°C)
LC 10/200-350/29 flexC Ip SNC4	14-29	200	37	5.8	80
		250		7.3	85
		300		8.7	85
		350		10.2	85

**Tested according to:** EN 61347-2-13:2014/A1:2017  
 EN 61347-1:2015/A1:2021  
 EN IEC 62384:2020

**Production Facility(ies):** 114313