

CERTIFICATE

No. U6 079054 0026 Rev. 02

Holder of Certificate: Tridonic GmbH & Co KG

Färbergasse 15
6851 Dornbirn
AUSTRIA

Certification Mark:




Product: Power supplies
(LED Driver)

The product was voluntarily tested according to the listed standards. The product can be marked with the certification mark shown above. It is not permitted to alter the certification mark in any way. In addition, the certificate holder must not transfer the certificate to third parties. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64142205001403

Date, 2023-12-22



(Taylor Yao)



CERTIFICATE

No. U6 079054 0026 Rev. 02

Model(s):

- LC 150 12V IP67 L EXC UNV;
- LC 150 24V IP67 L EXC UNV;
- LC 150 36V IP67 L EXC UNV;
- LC 150 48V IP67 L EXC UNV;
- LC 200 12V IP67 L EXC UNV;
- LC 200 24V IP67 L EXC UNV;
- LC 200 36V IP67 L EXC UNV;
- LC 200 48V IP67 L EXC UNV;
- LC 320 12V IP67 L EXC UNV;
- LC 320 24V IP67 L EXC UNV;
- LC 320 36V IP67 L EXC UNV;
- LC 320 48V IP67 L EXC UNV

Brand Name: TRIDONIC

TRIDONIC

Parameters:

Rated Input Voltage: 100-277VAC
 Rated Frequency: 50/60Hz
 Rated Input Current: See below table for details
 Rated Output: See below table for details
 Protection against Electric Shock: Class I; SELV
 Degree of Protection: IP67
 Method of Installation: Independent
 Type of Output: Constant voltage type
 ta: 50°C
 tc: 85°C



Product Service

CERTIFICATE

No. U6 079054 0026 Rev. 02

Model	Rated Input Current (Max. A)	U _{rated} (VDC)	Output Current (Max. A)	P _{rated} (Max. W)
LC 150 12V IP67 L EXC UNV	2.0	12	12.50	150
LC 150 24V IP67 L EXC UNV	2.0	24	6.25	150
LC 150 36V IP67 L EXC UNV	2.0	36	4.17	150
LC 150 48V IP67 L EXC UNV	2.0	48	3.13	150
LC 200 12V IP67 L EXC UNV	2.8	12	16.67	200
LC 200 24V IP67 L EXC UNV	2.8	24	8.33	200
LC 200 36V IP67 L EXC UNV	2.8	36	5.56	200
LC 200 48V IP67 L EXC UNV	2.8	48	4.17	200
LC 320 12V IP67 L EXC UNV	4.0	12	22.00	264
LC 320 24V IP67 L EXC UNV	4.0	24	13.33	320
LC 320 36V IP67 L EXC UNV	4.0	36	8.90	320
LC 320 48V IP67 L EXC UNV	4.0	48	6.67	320

Tested according to:

EN 61347-1:2015/A1:2021
EN 61347-2-13:2014/A1:2017
EN IEC 62384:2020

Production Facility(ies):

067179, 090733

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFIKAT ◆ CERTIFICAT