



File Ref: CS11225N
Contact: Admin Clerk
Telephone: 02 9372 8312

Phillip Lowe
Tridonic Australia Pty Ltd
2/7 Millner Ave
HORSLEY PARK NSW 2175

Dear Sir/Madam

CERTIFICATE OF SUITABILITY: CS11225N AND VARIATION/S

LED Driver

Please find enclosed a Certificate of Suitability and addendum as sought by your application.


Articles of the approved type may be marked with the mark (or alternate approval mark) shown on the Certificate.

THE APPROVAL EXPIRES ON THE DATE SHOWN ON THE CERTIFICATE unless it is renewed, extended, suspended or cancelled.

Yours faithfully

4 March 2024

For Secretary, Department of Customer Service



Electrical & Gas Approvals
PO Box 972, Parramatta NSW 2124
02 9372 8312

Email: energyapprovals@customerservice.nsw.gov.au
Website: www.fairtrading.nsw.gov.au



Certificate of Suitability Non-Declared Article

Pursuant to Section 16 (1) of the Gas and Electricity (Consumer Safety)
Act 2017

Certificate Number: **CS11225N**

This is to certify that the article specified below is accepted by NSW FAIR TRADING as suitable for connection to public electricity supply in NEW SOUTH WALES in accordance with the provisions of AS/NZS 3000 and subject to the condition stated.

Issued to:	Tridonic Australia Pty Ltd	
Article:	LED Driver [Built-in, Fixed Output Constant Voltage LED Driver with SELV output, for luminaires of protection class I and II, housed in metallic enclosure for indoor use]	
Trade Name or Mark:	TRIDONIC	
Ratings:	Volts: 220-240V Watts: 110W	Amperes: Hertz: 50/60HZ
	Other Name Plate Particulars: Class I, IP20, DC Output: Irated=4167mA; Uout=24V (no load); Prated=100W, Tc: 80 degree C, Ta: -20 degree C to +50 degree C	
Type Reference Code:	LC 100W 24V Ip SNC2	
Examined for Compliance With:	AS 61347.2.13:2018	
Nominated Marking:	CS11225N or approved alternate mark	
Date of Approval:	04/03/2024	
Approval Expires:	04/03/2029 unless suspended, cancelled, renewed or extended	

Condition: 1. This certificate is issued subject to the article and approved variations being maintained at the specification/s of the article examined at the time of approval.

4 March 2024



On behalf of the Secretary, Department of Customer Service
For information regarding currency of this model approval, refer to the Fair Trading Website



Ref: CS11225/1

**ADDENDUM TO CERTIFICATE OF SUITABILITY: CS11225N
Particulars of Modification(s)**

Model No. LC 35W 24V Ip SNC2 being similar to approved Model No. LC 100W 24V Ip SNC2 except for
Irated: 1458mA, Prated=35W

Model No. LC 60W 24V Ip SNC2 being similar to approved Model No. LC 100W 24V Ip SNC2 except for
Irated: 2500mA, Prated=60W, Tc: 70 degree C

This certificate will expire on 04/03/2029

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:

A handwritten signature in black ink, appearing to read "G. L. ...".

4 March 2024

For Secretary, Department of Customer Service

A large, light blue stylized flower graphic in the bottom left corner of the page.

Electrical & Gas Approvals
PO Box 972, Parramatta NSW 2124
02 9372 8312

Email: energyapprovals@customerservice.nsw.gov.au
Website: www.fairtrading.nsw.gov.au