

OVE Austrian Electrotechnical Association
Eschenbachgasse 9 | 1010 Wien | Austria
ZVR: 327279890 | www.ove.at



OVE Certification
Kahlenberger Str. 2A | 1190 Wien | Austria
T +43 1 370 58 06 | certification@ove.at

ENEC Certification Body registered under ID # 11.

Validity of ENEC Licences can be checked at www.enec.com

LICENCE

to use the European Mark



Licence No.: **7590-318**

Date of issue: Wien, 2022 06 30
Rev. No.: 04 Wien, 2024 05 17

OVE the Austrian Electrotechnical Association as signatory to the **"Agreement on the use of a commonly agreed Mark of Conformity for certain electrical equipment complying with European Standards"** hereby grants the right to label the products mentioned hereunder and listed in the Annex with the Mark(s) shown above to the following company

Licensee: **Tridonic GmbH & Co KG**
Färbergasse 15
6851 Dornbirn
Austria

Product: **Electronic control gears for LED-modules**

Trade Mark: **TRIDONIC**

Series/Type: **LCI ... NF ... PRE4, LC ... NF ... EXC4, LC ... NF ... PRE4, LCI ... NF ... EXC4**

Basis for this given right is the conformity of the products with the requirements of the relevant Standard(s) as listed in the Annex and the fulfilment of articles 8 and 9 of the ENEC-Agreement by the manufacturer. This licence refers to the tested specimen and to all products manufactured strictly identical to the submitted one.

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

Österreichischer Verband für Elektrotechnik
Head of OVE Certification

T. Neumayer

Digitally signed by T. Neumayer
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer



OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



<i>Hersteller</i> <i>Manufacturer</i>	Tridonic GmbH & Co KG Färbergasse 15 6851 Dornbirn Austria
<i>Fertigungsstätte(n)</i> <i>Factory location(s)</i>	ID: 7590 ID: 87468
<i>Typenbezeichnung</i> <i>Type reference</i>	LCI ... pD NF h28 PRE4, LC ... o4a NF h16 EXC4, LC ...D4i NF h16 PRE4, LCI ... o4a NF h28 EXC4, see page 4
* <i>Prüfbericht</i> <i>Test Report</i>	TR 7590-0026-01 ECS, TR 7590-0026-02 ECS, TR 7590-0029-01 ECS, TR 7590-0029-02 ECS, TR 7590-0120-01 ECS, TR 7590-0120-02 ECS, TR 7590-0121-01 ECS, TR 7590-0121-02 ECS, TR 7590-0122-01 ECS, TR 7590-0122-02 ECS, TR 7590-0120-01a ECS, TR 7590-0120-02a ECS
<i>Nationale Bestimmung(en)</i> <i>National Standard(s)</i>	OVE EN 61347-1:2021-09-01 OVE EN 61347-2-13:2017-11-01 OVE EN IEC 62384:2021-04-01
<i>Europannorm(en)</i> <i>European Standard(s)</i>	EN 61347-1:2015 + A1:2021 EN 61347-2-13:2014 + A1:2017 EN IEC 62384:2020
* <i>Ersatz für Zertifikat</i> <i>Superseded licence</i>	7590-318 Rev. 03 dated 2024 02 05 Items modified are marked with an asterisk (*)
<i>Anmerkung(en)</i> <i>Remark(s)</i>	Complies with the additional requirements for emergency lighting according Annex J of EN 61347-2-13:2014+A1:2017.

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

<i>Nennspannung</i> <i>Rated voltage</i>	AC 220-240 V, 50/60 Hz; DC 220-240 V
<i>Nennstrom (sec.)</i> <i>Rated current (sec.)</i>	see page 4
<i>Höchste Ausgangsspannung</i> <i>Max. output voltage</i>	see page 4
<i>Nennleistung</i> <i>Rated power</i>	see page 4
<i>Max. Betriebstemperatur t_c</i> <i>Rated max. operating temperature t_c</i>	see page 4
<i>Umgebungstemperatur t_a</i> <i>Rated ambient temperature t_a</i>	see page 4
<i>Maximale Gehäusetemperatur</i> <i>Rated maximum case temperature</i>	see page 4
<i>Kurzschlußschutz</i> <i>Short-circuit protection</i>	Short circuit proof control gear.
<i>Klassifikation</i> <i>Classification</i>	Built-in electronic control gears, constant current type.

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

TRADEMARK / TYPECODE		Classification B...Built-in	Rated output current	Maximum output voltage (no-load)	Rated output power	Rated max. operating temperature (tc) ¹	Maximum ambient temperature (ta) ¹	Maximum case temperature	Circuit power factor	Case
TRIDONIC										Metal (M) Plastic (P)
			[mA]	[V]	[W]	[°C]	[°C]	[°C]	λ	
1	LCI 220/500-1400/300 pD NF h28 PRE4	B	500-1400	320	220	87/88/89/92	65/70/75	130	0,86C-0,99	M
2	LC 90/150-400/330 o4a NF h16 EXC4	B	150-400	350	90	77/78/79	65/70	110	0,78C-0,99	M
3	LC 90/200-800/230 o4a NF h16 EXC4	B	200-800	250	90	79/81/85	65/70	110	0,55C-0,99	M
4	LC 120/350-1050/230 o4a NF h16 EXC4	B	350-1050	250	120	81/83/84/86	55/60/65	110	0,65C-0,99	M
5	LC 40/75-400/230 D4i NF h16 PRE4	B	75-400	250	40	79/80/81/82	55/60/65	110	0,43C - 0,98	M
6	LC 60/75-330/330 D4i NF h16 PRE4	B	75-330	350	60	80/81/82	55/60/65/70	110	0,67C - 0,99	M
7	LC 60/150-550/230 D4i NF h16 PRE4	B	150-550	250	60	80/81/84	50/55/60/65	110	0,64C - 0,99	M
8	LC 90/150-400/330 D4i NF h16 PRE4	B	150-400	350	90	81/82/83/84	65/70	110	0,68C - 0,98	M
9	LCI 105/200-850/300 pD NF h28 PRE4	B	200-850	320	105	85/88/90/91	75/80	130	0,61C - 0,98	M
10	LCI 150/250-1050/300 pD NF h28 PRE4	B	250-1050	320	150	87/89/90	70/75/80	130	0,63C - 0,99	M
11	LCI 75/125-550/300 o4a NF h28 EXC4	B	125-550	320	75	85/86/88/90/91	80	130	0,56C - 0,99	M
12	LCI 105/200-850/300 o4a NF h28 EXC4	B	200-850	320	105	82/85/87/89	70/80	130	0,66C - 0,99	M
13	LCI 150/250-1050/300 o4a NF h28 EXC4	B	250-1050	320	150	82/84/87/89	65/75/80	130	0,65C - 0,99	M

¹ Depending on selected output current, see label and/or datasheet.

OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.