

**OVE Austrian Electrotechnical Association**  
Eschenbachgasse 9 | 1010 Wien | Austria  
ZVR: 327279890 | www.ove.at



**OVE Certification**  
Kahlenberger Str. 2A | 1190 Wien | Austria  
T +43 1 370 58 06 | certification@ove.at

ENEC Certification Body registered under ID # 11.

Validity of ENEC Licences can be checked at [www.enec.com](http://www.enec.com)

# LICENCE

to use the European Mark



Licence No.: **7590-336**

Date of issue: Wien, 2023 02 24  
Rev. No.: 04 Wien, 2024 12 09

OVE the Austrian Electrotechnical Association as signatory to the **"Agreement on the use of a commonly agreed Mark of Conformity for certain electrical equipment complying with European Standards"** hereby grants the right to label the products mentioned hereunder and listed in the Annex with the Mark(s) shown above to the following company

Licensee: **Tridonic GmbH & Co KG**  
Färbergasse 15  
6851 Dornbirn  
Austria

Product: **Electronic control gears for LED-modules**

Trade Mark: **TRIDONIC**

Series/Type: **LC ... fixC .. SNC2**

Basis for this given right is the conformity of the products with the requirements of the relevant Standard(s) as listed in the Annex and the fulfilment of articles 8 and 9 of the ENEC-Agreement by the manufacturer. This licence refers to the tested specimen and to all products manufactured strictly identical to the submitted one.

This licence has been issued under the presumption and conditional on the fact that the licensee holds all necessary legal rights with regard to the product presented for testing and certification.

**Österreichischer Verband für Elektrotechnik**  
Head of OVE Certification

*T. Neumayer*

Digitally signed by T. Neumayer  
Email=t.neumayer@ove.at

Dipl.-Ing. T. Neumayer



## OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.



<i>Hersteller Manufacturer</i>	<b>Tridonic GmbH &amp; Co KG Färbergasse 15 6851 Dornbirn Austria</b>
<i>Fertigungsstätte(n) Factory location(s)</i>	<b>ID: 40926</b>
* <i>Typenbezeichnung Type reference</i>	<b>Series LC ... fixC SC SNC2, Series LC ... fixC SR SNC2, see pages 4 to 5</b>
* <i>Prüfbericht Test Report</i>	<b>TGM-VA EE 39315 ECS, TGM-VA EE 39316 ECS, TGM-VA EE 37528b ECS-1, TGM-VA EE 37529a ECS-1, TGM-VA EE 37557a ECS-1, TGM-VA EE 37558a ECS-1, TGM-VA EE 37559a ECS-1, TGM-VA EE 37560a ECS-1, TGM-VA EE 38899 ECS-1, TGM-VA EE 38898 ECS-1, TGM-VA EE 38900 ECS-1, TGM-VA EE 38901 ECS-1, TR 87837-0093-02 ECS, TR 87837-0094-02 ECS, TR 87837-0115-02 ECS, TR 87837-0116-02 ECS, TR 87837-0117-02 ECS, TR 87837-0118-02 ECS</b>
<i>Nationale Bestimmung(en) National Standard(s)</i>	<b>OVE EN 61347-1:2021-09-01 OVE EN 61347-2-13:2017-11-01 OVE EN IEC 62384:2021-04-01</b>
<i>Europannorm(en) European Standard(s)</i>	<b>EN 61347-1:2015 + A1:2021 EN 61347-2-13:2014 + A1:2017 EN IEC 62384:2020</b>
* <i>Ersatz für Zertifikat Superseded licence</i>	<b>7590-336 Rev. 03 dated 2024 02 02 Items modified are marked with an asterisk (*)</b>
<i>Anmerkung(en) Remark(s)</i>	<b>--</b>

## OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

<i>Nennspannung</i> <i>Rated voltage</i>	<b>220-240 V, 50/60 Hz</b>
* <i>Nennstrom (sec.)</i> <i>Rated current (sec.)</i>	<b>see pages 4 to 5</b>
* <i>Höchste Ausgangsspannung</i> <i>Max. output voltage</i>	<b>SELV, see pages 4 to 5</b>
* <i>Nennleistung</i> <i>Rated power</i>	<b>see pages 4 to 5</b>
<i>Schutzklasse</i> <i>Class of protection</i>	<b>CI.II (only for independent controlgears)</b>
* <i>Max. Betriebstemperatur tc</i> <i>Rated max. operating temperature tc</i>	<b>see pages 4 to 5</b>
<i>Maximale Gehäusetemperatur</i> <i>Rated maximum case temperature</i>	<b>110°C</b>
<i>Kurzschlußschutz</i> <i>Short-circuit protection</i>	<b>Inherently short circuit proof.</b>
<i>Klassifikation</i> <i>Classification</i>	<b>Electronic controlgears providing SELV with double or reinforced insulation for LED modules, constant current type.</b>

## OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

TRADEMARK / TYPECODE		Classification B...Built-in I...Independent	Rated output current	Maximum output voltage (no-load)	Rated output power	Rated max. operating temperature (tc)	Maximum ambient temperature (ta)	Maximum case temperature	Circuit power factor (230V, 50Hz, full load)	Case  Metall (M) Plastic (P)
TRIDONIC										
1	LC 30/350/86 fixC SR SNC2	I	350	100	30,1	75	50	110	0,9C-0,95	P
2	LC 30/350/86 fixC SC SNC2	B <sup>1</sup>	350	100	30,1	75	50	110	0,9C-0,95	P
3	LC 25/350/71 fixC SR SNC2	I	350	100	25	70	50	110	0,85C-0,93C	P
4	LC 25/700/36 fixC SR SNC2	I	700	50	25,2	70	50	110	0,85C-0,93C	P
5	LC 25/350/71 fixC SC SNC2	B <sup>1</sup>	350	100	25	70	50	110	0,85C-0,93C	P
6	LC 50/1200/42 fixC SR SNC2	I	1200	60	50,4	85	50	110	0,9C-0,95	P
7	LC 50/1200/42 fixC SC SNC2	B <sup>1</sup>	1200	60	50,4	85	50	110	0,9C-0,95	P
8	LC 60/700/86 fixC SR SNC2	I	700	100	60,2	85	50	110	0,9C-0,95	P
9	LC 60/1400/43 fixC SR SNC2	I	1400	60	60,2	85	50	110	0,9C-0,95	P
10	LC 60/700/86 fixC SC SNC2	B <sup>1</sup>	700	100	60,2	85	50	110	0,9C-0,95	P
11	LC 60/1400/43 fixC SC SNC2	B <sup>1</sup>	1400	60	60,2	85	50	110	0,9C-0,95	P
12	LC 8/180/44 fixC SR SNC2	I	180	100	8	75	50	110	0,45C-0,53C	P
13	LC 8/200/40 fixC SR SNC2	I	200	100	8	75	50	110	0,45C-0,53C	P
14	LC 10/250/40 fixC SR SNC2	I	250	100	10	80	50	110	0,5C-0,55C	P
15	LC 10/350/29 fixC SR SNC2	I	350	75	10	80	50	110	0,5C-0,55C	P
16	LC 10/500/20 fixC SR SNC2	I	500	60	10	80	50	110	0,5C-0,55C	P
17	LC 10/700/14.5 fixC SR SNC2	I	700	50	10	80	50	110	0,5C-0,55C	P
18	LC 15/300/50 fixC SR SNC2	I	300	85	15	80	50	110	0,48C-0,57C	P

### OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.

TRADEMARK / TYPECODE		Classification B...Built-in I...Independent	Rated output current	Maximum output voltage (no-load)	Rated output power	Rated max. operating temperature (tc)	Maximum ambient temperature (ta)	Maximum case temperature	Circuit power factor (230V, 50Hz, full load)	Case
TRIDONIC										
			[mA]	[V]	[W]	[°C]	[°C]	[°C]	$\lambda$	
19	LC 15/350/43 fixC SR SNC2	I	350	85	15	80	50	110	0,48C-0,57C	P
20	LC 20/450/43 fixC SR SNC2	I	450	60	19,35	65	50	110	0,8C-0,88C	P
21	LC 5/120/42 fixC SR SNC2	I	120	100	5	75	50	110	0,45C-0,5C	P
22	LC 7/150/47 fixC SR SNC2	I	150	120	7	80	50	110	0,45C-0,5C	P
23	LC 8/180/44 fixC SC SNC2	B <sup>1</sup>	180	100	8	75	50	110	0,45C-0,53C	P
24	LC 8/200/40 fixC SC SNC2	B <sup>1</sup>	200	100	8	75	50	110	0,45C-0,53C	P
25	LC 10/250/40 fixC SC SNC2	B <sup>1</sup>	250	100	10	80	50	110	0,5C-0,55C	P
26	LC 10/350/29 fixC SC SNC2	B <sup>1</sup>	350	75	10	80	50	110	0,5C-0,55C	P
27	LC 10/500/20 fixC SC SNC2	B <sup>1</sup>	500	60	10	80	50	110	0,5C-0,55C	P
28	LC 10/700/14.5 fixC SC SNC2	B <sup>1</sup>	700	50	10	80	50	110	0,5C-0,55C	P
29	LC 15/300/50 fixC SC SNC2	B <sup>1</sup>	300	85	15	80	50	110	0,48C-0,57C	P
30	LC 15/350/43 fixC SC SNC2	B <sup>1</sup>	350	85	15	80	50	110	0,48C-0,57C	P

<sup>1</sup> With strain reliefs and terminal cover also useable as independent controlgear

## OVE Certification

Accredited by the Austrian National Accreditation Body as Certification Body for products within the scope as given in the official decree and published under <https://akkreditierung-austria.gv.at>.