



中国国家强制性产品认证证书

证书编号：2025011002770871

认证委托人名称及地址

锐高照明电子（上海）有限公司
中国（上海）自由贸易试验区富特北路 215 号第二层 F12 部位

生产者名称及地址

锐高照明电子（上海）有限公司
中国（上海）自由贸易试验区富特北路 215 号第二层 F12 部位

生产企业名称及地址

锐高照明电子（深圳）有限公司
深圳市龙华区观澜街道库坑社区龙华大道 7301 号 A3 栋一层二层

产品名称和系列、型号、规格

LED 模块用交流电子控制装置（内装式（II类），恒流模式，隔离式，控制端口调光，定温热保护：130℃）
见附页。220-240V~50/60Hz

产品标准和技术要求

GB 17625.1-2022; GB/T 17743-2021; GB/T 19510.1-2023; GB/T 19510.213-2023
上述产品符合《强制性产品认证实施规则 照明电器》（CNCA-C10-01:2014）的要求，特发此证。

发证日期：2025 年 04 月 16 日 有效期至：2030 年 04 月 15 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

经中国合格评定国家认可委员会认可 CNAS C001-P



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号：2025011002770871

证书附页：第 1 页 共 1 页

序号	型号	输出电流 (mA)	最大输出 电压 (Vdc)	输出功 率 (W)	ta (°C)	tc (°C)
1	LCO 110/200-1050/157 pD+ NF C SNC	200...≤400	200	110	65	79
		>400...<700			60	79
		≥700...≤1050			55	77
2	LCO 110/200-700/220 pD+ NF C SNC	200...<300	280	110	60	78
		≥300...≤700			55	78

输入：220-240V~ 50/60Hz。

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2025011002770871

NAME AND ADDRESS OF THE APPLICANT

Tridonic (Shanghai) Co., Ltd.
F12, 2nd Floor, No.215, North Fute Road, China (Shanghai) Pilot Free Trade Zone, Shanghai City,
P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Tridonic (Shanghai) Co., Ltd.
F12, 2nd Floor, No.215, North Fute Road, China (Shanghai) Pilot Free Trade Zone, Shanghai City,
P.R.China

NAME AND LOCATION OF THE FACTORY

TridonicAtco (Shenzhen) Co., Ltd.
1-2F,Building A3, 7301 Longhua Avenue, Kukeng Community, Guanlan Street, Longhua District,
Shenzhen

PRODUCT NAME,MODEL AND SPECIFICATION

A.C. Supplied Electronic Controlgear For LED Modules (Built-in, Constant Current Mode, Isolating
Controlgear, Controlled Port Dimming, Temperature Declared Thermally Protected:130°C)
See Appendix. 220-240V ~ 50/60Hz

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 17625.1-2022;GB/T 17743-2021;GB/T 19510.1-2023;GB/T 19510.213-2023

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014).

Valid from: Apr.16,2025

Valid until: Apr.15,2030

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO. : 2025011002770871

Appendix: Page 1 of 1

序号	型号	输出电流 (mA)	最大输出 电压 (Vdc)	输出功 率 (W)	ta (°C)	tc (°C)
1	LCO 110/200-1050/157 pD+ NF C SNC	200...≤400	200	110	65	79
		>400...<700			60	79
		≥700...≤1050			55	77
2	LCO 110/200-700/220 pD+ NF C SNC	200...<300	280	110	60	78
		≥300...≤700			55	78

输入: 220-240V~ 50/60Hz。

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.