



中国国家强制性产品认证证书

证书编号：2025011002794174

认证委托人名称及地址

锐高照明电子（上海）有限公司
中国（上海）自由贸易试验区富特北路 215 号第二层 F12 部位

生产者名称及地址

锐高照明电子（上海）有限公司
中国（上海）自由贸易试验区富特北路 215 号第二层 F12 部位

生产企业名称及地址

Tridonic SRB d.o.o Nis (Palilula)
Ulica Cumtobel 1, Nis, Nis -Palilula, 18000 Nis, 塞尔维亚

产品名称和系列、型号、规格

LED 模块用直流或交流电子控制装置（LED 控制装置，独立式，控制端口调光，恒流模式，安全特低电压，II 类，IP20，定温热保护：110°C，EL，适宜直接安装在普通可燃材料表面）

见附页；220-240V~ 50/60Hz，220-240VDC

产品标准和技术要求

GB 17625.1-2022; GB/T 17743-2021; GB/T 19510.1-2023; GB/T 19510.213-2023

上述产品符合《强制性产品认证实施规则 照明电器》（CNCA-C10-01:2014）的要求，特发此证。

发证日期：2025 年 07 月 14 日 有效期至：2030 年 07 月 13 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。



签发：

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2025011002794174

NAME AND ADDRESS OF THE APPLICANT

Tridonic (Shanghai) Co., Ltd.
F12, 2nd Floor, No.215, North Fute Road, China (Shanghai) Pilot Free Trade Zone, Shanghai City,
P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Tridonic (Shanghai) Co., Ltd.
F12, 2nd Floor, No.215, North Fute Road, China (Shanghai) Pilot Free Trade Zone, Shanghai City,
P.R.China

NAME AND LOCATION OF THE FACTORY

Tridonic SRB d.o.o Nis (Palilula)
Ulica Cumtobel 1, Nis, Nis -Palilula,18000 Nis, Serbia

PRODUCT NAME,MODEL AND SPECIFICATION

A.C. or D.C. Supplied Electronic Controlgear for LED Modules (LED Controlgear, Independent,
Controlled Port Dimming, Constant Current Mode, SELV, Class II, IP20, Temperature Declared
Thermally Protected: 110°C, EL, Suitable for Direct Mounting on Normally Flammable Material
Surfaces)

See Appendix; 220-240V ~ 50/60Hz , 220-240VDC

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 17625.1-2022;GB/T 17743-2021;GB/T 19510.1-2023;GB/T 19510.213-2023

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014).

Valid from: Jul.14,2025

Valid until: Jul.13,2030

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





中国国家强制性产品认证证书

证书编号：2025011002794174

证书附页：第 1 页 共 2 页

序号	型号	输出电流 (mA)	最大输出电压 (Vdc)	最大输出功率 (W)	ta (°C)	tc (°C)
1	LC 13/50-300/54 o4a NF SR+ EXC4	≤50	60	12.5	70	87
		>50...110			70	88
		>110...170			70	89
		>170...231			70	89
		>231...300			70	87
2	LC 25/200-600/54 o4a NF SR+ EXC4	≤200	60	25.0	55	79
		>200...290			55	80
		>290...380			55	81
		>380...463			50	79
		>463...600			55	83
3	LC 44/425-1050/54 o4a NF SR+ EXC4	≤425	60	43.5	65	87
		>425...555			65	89
		>555...685			60	88
		>685...805			50	89
		>805...1050			50	88
4	LC 58/750-1400/54 o4a NF SR+ EXC4	≤750	60	58	70	86
		>750...860			65	84
		>860...970			60	83
		>970...1075			55	83
		>1075...1400			55	84
5	LC 13/50-300/54	≤50	60	12.5	70	89

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



中国国家强制性产品认证证书

证书编号：2025011002794174

证书附页：第 2 页 共 2 页

	o4a NF SR EXC4	>50...110			65	84
		>110...170			65	85
		>170...231			65	85
		>231...300			70	88
6	LC 25/200-600/54 o4a NF SR EXC4	≤200	60	25.0	55	77
		>200...290			55	78
		>290...380			50	75
		>380...463			50	76
		>463...600			55	80
7	LC 44/425-1050/54 o4a NF SR EXC4	≤425	60	43.5	65	89
		>425...555			60	87
		>555...685			55	85
		>685...805			50	84
		>805...1050			55	87
8	LC 58/750-1400/54 o4a NF SR EXC4	≤750	60	58	65	81
		>750...860			60	78
		>860...970			55	75
		>970...1075			50	73
		>1075...1400			50	74
输入：220-240V~ 50/60Hz，220-240VDC。						

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司