



File Ref: NSW29610
Contact: Admin Clerk
Telephone: 02 9372 8312

Phillip Lowe
Tridonic Australia Pty Ltd
2/7 Millner Ave
HORSLEY PARK NSW 2175

Dear Sir/Madam

CERTIFICATE OF APPROVAL: NSW29610 AND MODIFICATION/S

Power Supply or Charger

Please find enclosed a Certificate of Approval and addendum as sought by your application.

Articles of the approved type may now be marketed, provided they are marked with the mark (or alternate approval marks) shown on the Certificate.

THE APPROVAL EXPIRES ON THE DATE SHOWN ON THE CERTIFICATE unless it is renewed, extended, suspended or cancelled.

Yours faithfully,

For Secretary, Department of Customer Service



Certificate of Approval Declared Article

Pursuant to Section 16 (1) of the Gas and Electricity (Consumer Safety)
Act 2017

Certificate Number: NSW29610

Issued to:	Tridonic Australia Pty Ltd
Class of Article:	Power Supply or Charger
Description of Article:	LED Driver (Independent non-dimming LED driver with adjustable output, constant current, 'IC' classification, housed in thermoplastic enclosure, Class II with looping-in earth terminals.)
Trade Name or Mark:	TRIDONIC
Ratings:	Volts: 220-240Vac Watts: Amperes: 69mA Hertz: 50/60Hz Other Name Plate Particulars: Uout 60V; Irated 50 to 300mA; Prated 12.5W; Ta -20 to 65 Degree C or -20 to 60 Degree C; Tc 70 Degree C.
Type Reference Code:	LC 13/50-300/54 flexC NF SR EXC4
Examined for Compliance With:	AS 61347.2.13:2018 in conjunction with AS/NZS 61347.1:2016+A1
Approval Mark:	Each electrical article of the abovementioned type shall be marked with Approval Number NSW29610 or approved alternate mark
Date of Approval:	21/07/2025
Approval Expires:	21/07/2030 unless suspended, cancelled, renewed or extended
This certificate is issued subject to the article and approved modifications being maintained at the specification/s of the article examined at the time of approval.	



On behalf of the Secretary, Department of Customer Service
For information regarding currency of this model approval, refer to the Fair Trading Website

ADDENDUM TO CERTIFICATE OF APPROVAL: NSW29610 Particulars of Modification(s)

Model LC 13/50-300/54 flexC NF SR+ EXC4 is similar to approved Model LC 13/50-300/54 flexC NF SR EXC4 except for –

- a) Different power supply connection design;
- b) Different enclosure appearance;
- c) 'Do-not-cover' classification in lieu of 'IC' classification.

Model LC 25/200-600/54 flexC NF SR EXC4 is similar to approved Model LC 13/50-300/54 flexC NF SR EXC4 except for –

- a) Input: 125mA;
- b) Output: Irated 200 to 600mA; Prated 25W; Ta -20 to 55 Degree C or -20 to 50 Degree C; Tc 70 Degree C;
- c) 'Do-not-cover' classification in lieu of 'IC' classification.

Model LC 25/200-600/54 flexC NF SR+ EXC4 is similar to Model LC 25/200-600/54 flexC NF SR EXC4 except for –

- a) Different power supply connection design;
- b) Different enclosure appearance.

Model LC 44/425-1050/54 flexC NF SR EXC4 is similar to approved Model LC 13/50-300/54 flexC NF SR EXC4 except for –

- a) Input: 212mA;
- b) Output: Irated 425 to 1050mA; Prated 43.5W; Ta -20 to 55 Degree C or -20 to 50 Degree C; Tc 75 Degree C;
- c) 'Do-not-cover' classification in lieu of 'IC' classification.

