



File Ref: CS11319N
Contact: Admin Clerk
Telephone: 02 9372 8312

Phillip Lowe
Tridonic Australia Pty Ltd
2/7 Millner Ave
HORSLEY PARK NSW 2175

Dear Sir/Madam

CERTIFICATE OF SUITABILITY: CS11319N AND VARIATION/S

Led Driver

Please find enclosed a Certificate of Suitability and addendum as sought by your application.

Articles of the approved type may be marked with the mark (or alternate approval mark) shown on the Certificate.

THE APPROVAL EXPIRES ON THE DATE SHOWN ON THE CERTIFICATE unless it is renewed, extended, suspended or cancelled.

Yours faithfully

For Secretary, Department of Customer Service



Certificate of Suitability Non-Declared Article

Pursuant to Section 16 (1) of the Gas and Electricity (Consumer Safety)
Act 2017

Certificate Number: **CS11319N**

This is to certify that the article specified below is accepted by NSW FAIR TRADING as suitable for connection to public electricity supply in NEW SOUTH WALES in accordance with the provisions of AS/NZS 3000 and subject to the condition stated.

Issued to:	Tridonic Australia Pty Ltd	
Article:	LED Driver (Built-in dimming LED driver with SELV output, constant current, available for DALI and other dimming controls, housed in thermoplastic enclosure, Class I.)	
Trade Name or Mark:	TRIDONIC	
Ratings:	Volts: 220-240Vac Watts:	Amperes: 93.6 -125.6mA Hertz: 50/60Hz
	Other Name Plate Particulars: Uout 60Vdc; I rated 350 to 1050mA; Prated 25W; Ta -20 to 60 / 55 / 60 Degree C; Tc 90 / 90 / 85 Degree C.	
Type Reference Code:	LCA 25W 350-1050mA one4all C PRE	
Examined for Compliance With:	AS 61347.2.13:2018 in conjunction with AS/NZS 61347.1:2016+A1	
Nominated Marking:	CS11319N or approved alternate mark	
Date of Approval:	04/08/2025	
Approval Expires:	04/08/2030 unless suspended, cancelled, renewed or extended	

Condition:

1. This certificate is issued subject to the article and approved variations being maintained at the specification/s of the article examined at the time of approval.



On behalf of the Secretary, Department of Customer Service

For information regarding currency of this model approval, refer to the Fair Trading Website



Ref: CS11319/1

ADDENDUM TO CERTIFICATE OF SUITABILITY: CS11319N
Particulars of Modification(s)

Model LCA 45W 500-1400mA one4all C PRE is similar to approved Model LCA 25W 350-1050mA one4all C PRE except for -

- a) Input: 132 to 224mA;
- b) Output: Irated 500 to 1400mA; Prated 45W; Ta -20 to 50 Degree C; Tc 90 / 95 / 100 Degree C;

This certificate will expire on 04/08/2030

Approved pursuant to Clause 15 (1) of the Gas and Electricity (Consumer Safety) Regulation 2018:

For Secretary, Department of Customer Service