



# 产品认证证书

国家认监委批准号：CNCA-R-2011-159

证书编号：CVC25010016775

## 认证委托人名称及地址

锐高照明电子（上海）有限公司  
中国（上海）自由贸易试验区富特北路 215 号第二层 F12 部位

## 生产者（制造商）名称及地址

锐高照明电子（上海）有限公司  
中国（上海）自由贸易试验区富特北路 215 号第二层 F12 部位

## 生产企业名称及地址

广东施格纳电气有限公司  
广东省佛山市顺德区勒流街道江村村慧商三路 13 号 7 楼之一

## 产品名称和系列、规格、型号

灯具用电源导轨系统（导轨接合器（II 类），集成 LED 模块用交流电子控制装置（SELV 输出），适宜直接安装在普通可燃材料表面， $t_a: 35^{\circ}\text{C}$ ， $t_c: 75^{\circ}\text{C}$ ）  
见附件，220-240V~ 50/60Hz

## 产品标准和技术要求

GB/T 17743-2021, GB/T 13961-2008, GB 17625.1-2022, GB/T 7000.1-2023

## 认证模式

型式试验 + 初始工厂检查 + 获证后监督

上述产品符合 CVC01193-2022 《CVC 标志认证实施规则 灯具用电源导轨系统安全与电磁兼容认证》认证规则的要求，特发此证。

发证日期：2025 年 08 月 26 日 有效期至：2030 年 06 月 24 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的有效性及相关信息可通过网站（[www.cnca.gov.cn](http://www.cnca.gov.cn) 或 [www.cvc.org.cn](http://www.cvc.org.cn)）查询。

签发人：\_\_\_\_\_

罗军波

威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号（510663）

<http://www.cvc.org.cn>

电话：+86-20-32293722





# PRODUCT CERTIFICATE

国家认监委批准号: CNCA-R-2011-159

**No.: CVC25010016775**

## NAME AND ADDRESS OF THE APPLICANT

Tridonic (Shanghai) Co., Ltd.  
F12, 2nd Floor, No.215, North Fute Road, China (Shanghai) Pilot Free Trade Zone, Shanghai City,  
P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

Tridonic (Shanghai) Co., Ltd.  
F12, 2nd Floor, No.215, North Fute Road, China (Shanghai) Pilot Free Trade Zone, Shanghai City,  
P.R.China

## NAME AND ADDRESS OF THE FACTORY

Guangdong Schigna Electric Co., Ltd  
7th Floor, No. 13, Cun Huishang 3rd Road, Jiangcun Village, Leliu Street, Shunde District,  
Foshan,Guangdong

## NAME, MODEL AND SPECIFICATION

Electrical Supply Track System For Luminaires (Track Coupler, Integrated With A.C. Supplied  
Electronic Controlgear For LED Modules, ta:35°C, tc:75°C)  
See appendix, 220-240V ~ 50/60Hz

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 17743-2021,GB/T 13961-2008,GB 17625.1-2022,GB/T 7000.1-2023

## CERTIFICATION MODEL

Type Test of Product + Initial Factory Inspection + Surveillance after Certification

This is to certify that the above mentioned products have met the Requirements of implementation  
rules CVC01193-2022 .

Date of issue: 2025-08-26 Date of expiry: 2030-06-24

Validity of this certificate is subject to positive result of the regular follow up inspection by  
issuing certification body until the expiry date.

The validity and information of the certificate can be verified through the website ([www.cnca.gov.cn](http://www.cnca.gov.cn) or  
[www.cvc.org.cn](http://www.cvc.org.cn)).

Issued by:



**CVC Certification & Testing Co., Ltd.**

No.3, Tiantaiyi Road, High-tech Industrial Development Zone, Science City, Guangzhou (510663) P. R. China

<http://www.cvc.org.cn>

Tel: +86-20-32293722





# 产品认证证书

国家认监委批准号：CNCA-R-2011-159

证书编号：CVC25010016775

证书附页：第 1 页 共 2 页

序号	产品型号	使用的LED控制装置		外壳颜色
		型号	参数	
1	LC 42/300-1050/42 flexC T-B SNC4	LC 42/300-1050/42 flexC T-B SNC4	输入：220-240V~，50/60Hz， Max. 0.23A，λ：0.51C-0.98；输出： 300-1050mA（恒流，电流可调）， Uout=59Vdc，配套光源：12.6W-42W LED 模块；整体式，t <sub>c</sub> :75°C，SELV， 	黑色
2	LC 42/300-1050/42 flexC T-W SNC4	LC 42/300-1050/42 flexC T-W SNC4		白色
3	LC 42/300-1050/42 flexC T-G SNC4	LC 42/300-1050/42 flexC T-G SNC4		灰色
4	LC 18/200-450/40 flexC T-B SNC4	LC 18/200-450/40 flexC T-B SNC4	输入：220-240V~，50/60Hz， Max. 0.10A，λ：0.75C-0.95；输出： 200-450mA（恒流，电流可调）， Uout=59Vdc，配套光源：8W-18W LED 模块；整体式，t <sub>c</sub> :75°C，SELV， 	黑色
5	LC 18/200-450/40 flexC T-W SNC4	LC 18/200-450/40 flexC T-W SNC4		白色
6	LC 18/200-450/40 flexC T-G SNC4	LC 18/200-450/40 flexC T-G SNC4		灰色

输入：220-240V~，50/60Hz，IP20，II类，集成LED模块用交流电子控制装置（SELV输出），适宜直接安装在普通可燃材料表面，t<sub>a</sub>:35°C，t<sub>c</sub>:75°C

拨码开关：

LC 42/300-1050/42 flexC T-B SNC4、LC 42/300-1050/42 flexC T-W SNC4、LC 42/300-1050/42 flexC T-G SNC4

Pout (W)	Iout (mA)	1	2	3	4	Pout (W)	Iout (mA)	1	2	3	4
12.6	300	—	—	—	—	29.4	700	ON	—	—	—
14.7	350	—	—	—	ON	31.5	750	ON	—	—	ON
16.8	400	—	—	ON	—	33.6	800	ON	—	ON	—
18.9	450	—	—	ON	ON	34.0	850	ON	—	ON	ON
21.0	500	—	ON	—	—	36.0	900	ON	ON	—	—
23.1	550	—	ON	—	ON	38.0	950	ON	ON	—	ON

注：此附录与证书同时使用时有效。

签发人：\_\_\_\_\_

## 威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号（510663）

<http://www.cvc.org.cn>

电话：+86-20-32293722





# 产品认证证书

国家认监委批准号：CNCA-R-2011-159

证书编号：CVC25010016775

证书附页：第 2 页 共 2 页

25.2	600	—	ON	ON	—	40.0	1000	ON	ON	ON	—
27.3	650	—	ON	ON	ON	42.0	1050	ON	ON	ON	ON

LC 18/200-450/40 flexC T-B SNC4、LC 18/200-450/40 flexC T-W SNC4、LC 18/200-450/40 flexC T-G SNC4

Pout (W)	Iout (mA)	1	2
8.0	200	—	—
10.0	250	—	ON
16.0	400	ON	—
18.0	450	ON	ON

注：此附录与证书同时使用时有效。

签发人：\_\_\_\_\_

威凯认证检测有限公司

中国·广州·高新技术产业开发区天泰一路3号 (510663)

<http://www.cvc.org.cn>

电话：+86-20-32293722

