

Australia and New Zealand Certificate of Suitability

Certificate
ULL-104309

Issue date
2026-01-14

Expiration date
2031-01-14



www.jasanz.org/register

This is to acknowledge that

TRIDONIC GmbH & Co KG

Faerbergasse 15, Dornbirn 6851
Austria

has had

Independent Non-SELV controlgear

[refer following page(s) for models list]

evaluated and meets the requirements of the standard(s)

**AS 61347.2.13:2018; AS/NZS 61347.1:2016,
Amd 1: 2018, Amd 2: 2025**

ANZ Certification Scheme requirements.



Stuart Foster (Certification Officer)

Certification Body:
UL International New Zealand Limited,
54 Tarndale Grove, Albany, Auckland 0632, New Zealand.

Issued for use in Australia and New Zealand only.
All dates are in Year-Month-Day format (YYYY-MM-DD).

Australia and New Zealand Certificate of Suitability

Certificate No: ULL-104309

Date of Issue/Revision: 2026-01-14

Trade Name or Trademark: TRIDONIC

Risk Class / NSW Declared Class: EESS OUT OF SCOPE - Non-prescribed / non-declared - Commercial (not certified for residential or household use)

IEC Standard Country Differences: AU and NZ

Certification Marking: The RCM may be applied to the product and all the requirements of all relevant parts of AS/NZS 4417 applicable to the article shall be fulfilled.

Additional Certification Conditions: Non-IC rated lighting equipment - commercial use only (refer EESS notice 20-007).

Model Details:

Model Name
LCO 600/600-2800/286 NF DA C PRE
LCO 800/850-4200/286 NF DA C PRE

Additional Information:

Rating :

Model : LCO 600/600-2800/286 NF DA C PRE

Input : 200-277 Vac, 5.7 A, 680 W

Output : 300 Vdc, 2.8 A, 600 W

Model : LCO 800/850-4200/286 NF DA C PRE

Input : 200-277 Vac, 7.7 A, 890 W

Output : 300 Vdc, 4.2 A, 800 W