



中国国家强制性产品认证证书

证书编号：2024011002610416

认证委托人名称及地址

锐高照明电子（上海）有限公司
中国（上海）自由贸易试验区富特北路 215 号第二层 F12 部位

生产者名称及地址

锐高照明电子（上海）有限公司
中国（上海）自由贸易试验区富特北路 215 号第二层 F12 部位

生产企业名称及地址

Tridonic GmbH & Co KG
Farbergasse 15, A-6851 Dornbirn, 奥地利

产品名称和系列、型号、规格

LED 模块用直流或交流电子控制装置（LED 控制装置，内装式，恒流模式，自耦式，控制端口调光，定温热保护：130℃，EL）
见附页；输入：220-240V~ 50/60Hz；220-240VDC。

产品标准和技术要求

GB 17625.1-2022；GB/T 17743-2021；GB/T 19510.1-2023；GB/T 19510.213-2023

上述产品符合《强制性产品认证实施规则 照明电器》（CNCA-C10-01:2014）的要求，特发此证。

发证日期：2026 年 03 月 27 日 有效期至：2029 年 02 月 27 日

本证书为变更证书，证书首次颁发日期：2024 年 02 月 29 日
证书信息和有效性可扫描下方二维码或登录发证机构网站查验，
也可在认监委网站（www.cnca.gov.cn）查询。

经中国合格评定国家认可委员会认可 CNAS C001-P



签发：

刘江



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024011002610416

NAME AND ADDRESS OF THE APPLICANT

Tridonic (Shanghai) Co., Ltd.
F12, 2nd Floor, No.215, North Fute Road, China (Shanghai) Pilot Free Trade Zone, Shanghai City,
P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Tridonic (Shanghai) Co., Ltd.
F12, 2nd Floor, No.215, North Fute Road, China (Shanghai) Pilot Free Trade Zone, Shanghai City,
P.R.China

NAME AND LOCATION OF THE FACTORY

Tridonic GmbH & Co KG
Farbergasse 15, A-6851 Dornbirn, Austria

PRODUCT NAME,MODEL AND SPECIFICATION

A.C. or D.C. Supplied Electronic Controlgear For LED Modules (LED Controlgear, Built-in, Constant
Current Mode, Auto-wound Controlgear, Controlled Port Dimming, Temperature Declared Thermally
Protected: 130°C, EL)
See Appendix; Input : 220-240V ~ 50/60Hz ; 220-240VDC.

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 17625.1-2022;GB/T 17743-2021;GB/T 19510.1-2023;GB/T 19510.213-2023
This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C10-01:2014).

Valid from: Mar.27,2026 **Valid until:** Feb.27,2029
Date of original issued: Feb.29,2024

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P



SIGNATURE:



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE



CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



中国国家强制性产品认证证书

证书编号：2024011002610416

证书附页：第 1 页 共 1 页

型号	输出电流 (mA)	最大输出电压 (Vdc)	最大输出 功率 (W)	tc
LCI 150/250-1050/30 0 pD NF h28 PRE4	≤250	320	150	87°C
	>250...400			89°C
	>400...600			87°C
	>600...800			90°C
	>800...1050			90°C
LCI 105/200-850/300 pD NF h28 PRE4	≤200	320	105	85°C
	>200...400			88°C
	>400...550			91°C
	>550...700			88°C
	>700...850			90°C

输入：220-240V~ 50/60Hz；220-240VDC。

本页为证书附页，应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司